

ALL-STATE WELL TESTING SERVICES, LLC

11-13 BROAD STREET, WASHINGTON, NEW JERSEY 07882, (908) 835-2510

Laboratory Cert# 21016

Report Date: 06/23/25

Project: 535 Fisher Avenue, Phillipsburg Township, Phillipsburg NJ 08865

Sample Date/Time: 06/12/25

Technician: Brielle Sweigert

Treatment: None (City Water)

Norwescap Head Start

Collection Point: Classroom #2

Sample Time: 15:17

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	07010	06/17/25 08:32

Collection Point: Classroom #1

Sample Time: 15:19

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	07010	06/17/25 08:36

Collection Point: Kitchen Tap

Sample Time: 15:20

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	07010	06/17/25 08:41

Analytical results **ARE** below the Action Level (AL) of 15 ug/L for lead

I certify that these test results are technically complete, and all procedures follow the analytical methods identified.



Harold Blaine
Laboratory Manager